


GRILLES, REGISTERS & DIFFUSERS SCHEDULE

DIFFUSER TYPE 				
TAG	DIFFUSER/GRILLE TYPE	CFM RANGE	NECK INLET SIZE	SIZE
SG1	SIDEWALL SUPPLY GRILLE	0-160	-	8x6
SG2	SIDEWALL SUPPLY GRILLE	170-220	-	10x6
SG3	SIDEWALL SUPPLY GRILLE	200-280	-	12x6
SD1	CEILING DIFFUSER	130-240	-	9x9
SD2	CEILING DIFFUSER	250-450	-	12x12
SD3	CEILING DIFFUSER	0-120	-	6x6
SD4	CEILING DIFFUSER	460-620	-	15x15
RG1	RETURN GRILLE	0-200	-	12x6
RG2	RETURN GRILLE	0-360	-	20x6
RG3	RETURN GRILLE	0-600	-	18x10
RG4	RETURN GRILLE	0-500	-	12x12
RG5	RETURN GRILLE	0-420	-	12x10
RG6	KICKSPACE RETURN GRILLE	0-200	-	30x3
RG7	FLOOR RETURN GRILLE	0-300	-	30x6
RG8	KICKSPACE RETURN GRILLE	0-140	-	20x3
RG9	RETURN GRILLE	0-800	-	18x12
RG10	RETURN GRILLE	0-1200	-	24x10

**Allied Consulting**  
 Engineering Services, Inc.  
 215 Boston Post Road, Sudbury, MA  
 Tel: (978) 443-7888  
 Fax: (978) 443-4636

RUSSELL TREMAINE  
 ARCHITECT

MAY 16, 2008

5 & 6 BRIGHAM STREET  
 EAST BOSTON, MA

HVAC FOURTH  
 FLOOR PLAN

1/4" = 1' 0"

H5